

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0809 - CPR - 19006044 - C6

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Textile floor coverings

intended for interior use

Product names:

**Ex-dono Quartet TEXtiles, Symphony TEXtiles, Zenith TEXtiles,
Eventi EcoTiles, Framework EcoTiles, Penta EcoTiles, Presswork 1100 EcoTiles**

Tufted, latex-free PA tiles with felt backing

with reaction to fire classification according to EN 13501-1:

B_{fl}-s1

glued with acrylate-copolymer dispersion adhesive or loose laid on class A1 or A2-s1, d0 substrate as specified in Annex 1, which forms part of this certificate.

Placed on the market under the name or trade mark of

Fletco Carpets A/S

Mads Clausens Vej 2
DK-7441 Bording, Denmark

and produced in the manufacturing plant

Fletco Carpets.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14041:2004

and

EN 14041:2004/AC:2006

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on December 16, 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The validity of the certificate may be confirmed at the web address www.sertifikaattihaku.fi.

Espoo May 12, 2020

Heli Välimäki
Senior Expert

Tiina Tirkkonen
Senior Expert

Certificate No. 0809-CPR-19006044-C6

Annex 1

Product name	Reaction to fire classification
Ex-dono Quartet TEXtiles Symphony TEXtiles Zenith TEXtiles	B_{fl}-s1 loose laid or glued with acrylate-copolymer dispersion adhesive on class A1 or A2-s1, d0 substrate.
Eventi EcoTiles Framework EcoTiles Penta EcoTiles Presswork 1100 EcoTiles	B_{fl}-s1 glued with acrylate-copolymer dispersion adhesive on class A1 or A2-s1, d0 substrate.